Permit No.: TV01-01 Expiration Date: 12/31/01 Page 1 of 8 Pages

MONTEREY BAY UNIFIED AIR POLLUTION CONTROL DISTRICT TITLE V OPERATING PERMIT

24580 Silver Cloud Court Monterey, CA 93940 Telephone: (408) 647-9411

ISSUED TO:	
Pacific Energy - Crazy Horse Canyon Landfill P.O. Box 30900 Los Angeles, CA 90030	
PLANT SITE LOCATION:	
350 Crazy Horse Canyon Road Salinas, CA 93907	
ISSUED BY:	
Douglas Quetin, Air Pollution Control Officer	Date
Nature of Business: Landfill gas to energy facility	
SIC Code: 4911 - Electric Power Generation	

FACILITY CONTACT PERSON:

Name: Paul Nakamoto Title: Vice President Phone: (213) 895-5677

RESPONSIBLE OFFICIAL:

Name: Paul Scott

Title: Regional Supervisor Phone: (408) 663-6145

Permit No.: TV01-01 Expiration Date: 12/31/01 Page 2 of 8 Pages

FACILITY DESCRIPTION	3
EQUIPMENT DESCRIPTION	3
FEDERALLY ENFORCEABLE EMISSION LIMITS AND STANDARDS	3
FUTURE FEDERALLY ENFORCEABLE EMISSION LIMITS AND STANDARDS	4
TESTING REQUIREMENTS AND PROCEDURES	4
RECORD KEEPING REQUIREMENTS	5
REPORTING REQUIREMENTS	6
GENERAL CONDITIONS	7

Permit No.: TV01-01 Expiration Date: 12/31/01 Page 3 of 8 Pages

FACILITY DESCRIPTION

Pacific Energy's Crazy Horse Canyon facility is an alternative energy facility. This facility recovers and utilizes landfill gas from the Crazy Horse Landfill in an internal combustion engine which drives a generator to create electricity. The electricity generated is then sold to the local utility company.

EQUIPMENT DESCRIPTION

INTERNAL COMBUSTION ENGINE GENERATOR SET UTILIZING LANDFILL GAS CONSISTING OF:

- 1. "Clean Burn" Engine, M.E.P. Industries Model MEP-8T, Opposed Piston, Turbocharged-Intercooled, Eight Cylinders, Rated 2,200 Horsepower-Hour At 900 RPM.
- 2. Generator, Rated At 1,500 Kw.
- 3. Landfill Condensate Evaporation System.

FEDERALLY ENFORCEABLE EMISSION LIMITS AND STANDARDS

1. The mass emission rates from the facility shall not exceed the following mass emission limits [District Rule 207, District Rule 404 NOx limits of 140 lbs/hr and 350 ppm]:

Pollutant	Lbs/Hour	Lbs/Day
Oxides of Nitrogen	6.25	150.0
Carbon Monoxide	22.90	550.0
Non-methane Hydrocarbons	6.25	150.0

- 2. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three (3) minutes in any one (1) hour which is as dark or darker than Ringelmann 1 or equivalent 20% opacity. [District Rule 400]
- 3. Particulate matter shall not exceed 0.15 grains per standard dry cubic foot in the exhaust stream. [District Rule 403]
- 4. Sulfur compounds calculated as sulfur dioxide (SO₂) shall not exceed 0.2 percent by volume in the exhaust stream. [District Rule 404]
- 5. The landfill gas combusted shall contain no more than 50 grains of sulfur compounds (calculated as hydrogen sulfide) per 100 cubic feet of gas. [District Rule 412]

FUTURE FEDERALLY ENFORCEABLE EMISSION LIMITS AND STANDARDS

Permit No.: TV01-01 Expiration Date: 12/31/01 Page 4 of 8 Pages

6. As required in Section 60.756(d) of the New Source Performance Standard (NSPS) for Municipal Solid Waste (MSW) Landfills, Pacific Energy shall provide information describing the operation of the control device, the operating parameters that would indicate proper performance, and appropriate monitoring procedures to the City of Salinas for incorporation into the City of Salinas's landfill gas collection and control system design submittal. [40 CFR Part 60, Subpart WWW]

- 7. No later than 18 months after submittal of the City of Salinas' collection and control system design plan as required in Section 60.752(b)(2)(i) of the NSPS for MSW Landfills, Pacific Energy shall either reduce non-methane organic compounds (NMOC) by 98 weight-percent or reduce the NMOC outlet concentration to less than 20 ppmv, dry basis as hexane at 3% oxygen as required in Section 60.752(b)(2)(iii) of the NSPS for MSW Landfills. [40 CFR Part 60, Subpart WWW]
- 8. Pacific Energy shall operate the control device at all times that the collected gas is routed to the control device operated by Pacific Energy as required in Section 60.753(f) of the NSPS for MSW Landfills. [40 CFR Part 60, Subpart WWW]
- 9. As allowed for in Section 60.755(e) of the NSPS for MSW Landfills, conditions 7 and 8 do not apply to Pacific Energy's control device during periods of start-up, shutdown, or malfunction, provided that the duration of start-up, shutdown, or malfunction shall not exceed 1 hour. [40 CFR Part 60, Subpart WWW]

TESTING REQUIREMENTS AND PROCEDURES

- 10. Semiannual performance testing of the engine shall be conducted in June and December of each year. Pacific Energy shall conduct performance tests in accordance with CARB Method 100 to verify compliance with condition numbers 1 and 4. Pacific Energy shall furnish the District written results of such performance tests within thirty (30) days of the test completion. Written notice of the performance test shall be provided to the District a minimum of ten (10) days prior to the test so that a District observer may be present.
- Semiannual testing of the landfill gas to determine the sulfur content shall be completed during the months of June and December. Pacific Energy shall conduct testing in accordance with ASTM D 1072-80, ASTM D 3031-81, ASTM D 3246-81 or SCAQMD Method 307-91 to verify compliance with condition number 5. Pacific Energy shall furnish the District written results of the test within thirty (30) days of completion.
- 12. No testing is specified for the generic (Rule 400) opacity requirement from condition number 2. The engine is assumed to be in compliance with the opacity requirement due to its being fired on gaseous fuel. If testing is conducted for condition number 2, Pacific Energy should conduct testing in accordance with the methodology contained in EPA Method 9 and the averaging/aggregating period contained in District Rule 400.

Permit No.: TV01-01 Expiration Date: 12/31/01 Page 5 of 8 Pages

13. No testing is specified for the generic (Rule 403) particulate matter emission standard from condition number 3. The engine is assumed to be in compliance with the particulate matter emission standard due to its being fired on gaseous fuel. If testing is conducted for condition number 3, Pacific Energy should conduct testing in accordance with the methodology contained in EPA Method 5.

14. As required in 40 CFR Part 60.8 (NSPS General Provisions), Pacific Energy shall complete an initial performance test within 180 days after the control system operational deadline established by condition number 7. EPA test method 18 or 25, as specified in Section 60.754(d) of the NSPS for MSW Landfills (40 CFR Part 60, Subpart WWW), shall be used for this initial performance test to verify compliance with the emission limits contained in condition number 7.

RECORD KEEPING REQUIREMENTS

- 15. As required in Section 60.757(f) of the NSPS for MSW Landfills, Pacific Energy shall maintain the following specific monitoring records:
 - A) the value and length of time for exceedances of applicable parameters monitored under Section 60.756(d) and specified in the design plan submittal; and
 - B) a description and the duration of all times when the control device was not operating for any period exceeding 1 hour and the length of time the control device was not operating.
- 16. As applicable Pacific Energy shall maintain the following general records of required monitoring information:
 - A) the date and time of sampling or measurements;
 - B) the date(s) analyses were performed;
 - C) the company or entity that performed the analyses;
 - D) the analytical techniques or methods used;
 - E) the results of such analyses:
 - F) the operating conditions existing at the time of sampling or measurement; and
 - G) the records of quality assurance for continuous monitoring systems (including, but not limited to quality control activities, audits, and calibration drift checks) and source testing methods.
- 17. Pacific Energy shall maintain records on the occurrence and duration of any start-up, shutdown, or malfunction in the operation of the equipment under this permit.
- 18. Pacific Energy shall retain records of all required monitoring data and support information for a period of at least five (5) years from the date of the monitoring, sample collection, measurement, report, and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit.

Permit No.: TV01-01 Expiration Date: 12/31/01 Page 6 of 8 Pages

REPORTING REQUIREMENTS

19. Pacific Energy shall submit semiannual monitoring reports to the District, in a District approved format, no later than August 15 for the period of January 1 through June 30 and no later than February 15 for the period of July 1 through December 31.

These monitoring reports shall include at a minimum:

- the time intervals, date and magnitude of excess emissions, nature and cause of the excess (if known), corrective actions and preventative measures adopted; and
- B) the averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard for the pollutant in question; and
- C) all information pertaining to any monitoring as required by the permit; and
- D) a negative declaration specifying when no excess emissions occurred.
- 20. Pacific Energy shall submit an annual compliance certification report to the District and U.S. EPA, in a District approved format, no later than February 15 for the period of January 1 through December 31 of the preceding year.

This report shall include a written statement from the responsible official which certifies the truth, accuracy, and completeness of the report and shall include at a minimum:

- A) identification of each term or condition of the permit that is the basis of the certification; and
- B) the compliance status; and
- C) whether compliance was continuous or intermittent; and
- D) the method(s) used for determining the compliance status of the source, currently and over the reporting period.

GENERAL CONDITIONS

- 21. Pacific Energy shall comply with all conditions of this federal operating permit. Any noncompliance with a permit condition constitutes a violation of the Federal Clean Air Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.
- 22. In an enforcement action, the fact that Pacific Energy would have to halt or reduce the permitted

Permit No.: TV01-01 Expiration Date: 12/31/01 Page 7 of 8 Pages

activity in order to maintain compliance with the conditions of this permit is not a defense.

- 23. This permit may be modified, revoked, reopened and reissued, or terminated for cause as determined by the District. The filing of a request by Pacific Energy for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition.
- 24. This permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of federal, state, or local laws or regulations.
- 25. Pacific Energy shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit, or to determine compliance with the permit. Upon request, Pacific Energy shall also furnish to the District copies of records required to be retained by this permit.
- 26. For applicable requirements that will become effective during the permit term, Pacific Energy shall meet such requirements on a timely basis unless a more detailed schedule is expressly required by the applicable requirement.
- 27. Any document submitted to the District pursuant to this permit shall contain certification by the responsible official of truth, accuracy and completeness. All certifications shall state that based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete. Pacific Energy shall promptly, upon discovery, report to the District a material error or omission in these records, reports, plans, or other documents.
- 28. Pacific Energy shall report any violation of any requirement contained in this permit to the District within 96 hours after such occurrence. The violation report shall include the time intervals, date and magnitude of excess emissions; nature and cause of the excess (if known), corrective actions and preventive measures adopted.
- 29. Upon any administrative or judicial challenge, all the emission limits, specific and general conditions, monitoring, record keeping, and reporting requirements of this permit, except those being challenged, remain valid and must be complied with.
- 30. For this federal operating permit to remain valid through the permit term of five years from the date of issuance, Pacific Energy shall pay an annual emission fee based upon the requirements of District Rule 308.
- 31. Pacific Energy shall have available at the facility at all times a copy of this federal operating permit.

Permit No.: TV01-01 Expiration Date: 12/31/01 Page 8 of 8 Pages

- 32. For protection from enforcement action based upon an emergency, as defined in District Rule 218, the responsible official for Pacific Energy shall submit to the District relevant evidence which demonstrates:
 - A) an emergency occurred; and
 - B) that Pacific Energy can identify the cause(s) of the emergency; and
 - C) that the facility was being properly operated at the time of the emergency; and
 - D) that all steps were taken to minimize the emissions resulting from the emergency; and
 - E) within two working days of the emergency event, Pacific Energy provided the District with a description of the emergency and any mitigating or corrective actions taken.
- 33. Upon presentation of credentials, Pacific Energy shall allow the District, the ARB, the EPA, or an authorized representative, to perform the following:
 - enter upon the premises where the federal operating permit source is located or in which any records are required to be kept under the terms and conditions of this federal operating permit;
 - B) to have access to and copy any records required to be kept under the terms and conditions of this federal operating permit;
 - C) to inspect any equipment, operation, or process described or required in this federal operating permit; and,
 - D) to sample emissions from the source.
